

SWIMMING POOL - WATER SAMPLE READINGS

Day	Date	Time	POOL	Old Palintest Kit		Calcium Hypochlorite Kg or Scoop	New Palintest Kit		Calcium Hypochlorite Kg or Scoop	Readings Done by	Calcium Hypochlorite Kg or Scoop Info to ISS	ISS - Acknowledge Kg or Scoop of Calcium Hypochlorite for Daily Manual Dosing using	REMARKS
				Free Chlorine	pH		Free Chlorine	pH					
Thursday	01-Mar-18	7.15am	Main	-	-	-	-	-	10 Kg	Hj Said	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		11.00am	Splash Pool	1.30	7.30	-	-	-	1.5 Kq	Hj Said	-	-	-
Friday	02-Mar-18	7.15am	Main	-	-	-	2.40	7.80	10 Kg	Hj Said	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		-	Small	-	-	-	2.30	7.60	1.5 Kq	Hj Said	-	-	-
-	-	-	Splash Pool	-	-	-	-	-	-	Hj Said	-	-	Today no pool reading taken due pump failure at KBBC
Monday	05-Mar-18	7.15am	Main	-	-	-	2.40	7.70	10 Kg	Hj Said	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		-	Small	-	-	-	1.98	7.70	1.5 Kq	Hj Said	-	-	-
-	-	-	Splash Pool	-	-	-	-	-	-	Hj Said	-	-	Today no pool reading taken due pump failure at KBBC
Tuesday	06-Mar-18	7.30am	Main	-	-	-	2.00	7.85	10 Kg	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		-	Small	-	-	-	3.10	7.50	1.5 Kq	James	-	-	-
-	-	-	Splash Pool	-	-	-	-	-	-	James	-	-	Today no pool reading taken due pump failure at KBBC
Wednesday	07-Mar-18	7.24am	Main	-	-	-	2.04	7.95	10 Kg	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		-	Small	-	-	-	2.50	8.05	1.5 Kq	James	-	-	-
-	-	-	Splash Pool	-	-	-	-	-	-	James	-	-	Today no pool reading taken due pump failure at KBBC
Thursday	08-Mar-18	7.30am	Main	-	-	-	2.10	7.60	10 Kg	Kamarau	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		-	Small	-	-	-	1.96	7.90	1.5 Kq	Kamarau	-	-	-
-	-	-	Splash Pool	-	-	-	-	-	-	Kamarau	-	-	Today no pool reading taken due pump failure at KBBC
Friday	09-Mar-18	7.15am	Main	-	-	-	3.20	7.80	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		-	Small	-	-	-	3.30	8.00	1 Scoop&300g	James	-	-	-
-	-	-	Splash Pool	-	-	-	-	-	-	James	-	-	Today no pool reading taken due pump failure at KBBC
Monday	12-Mar-18	7.36am	Main	-	-	-	2.20	7.70	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		-	Small	-	-	-	2.80	7.75	1 Scoop&300g	James	-	-	-
-	-	-	Splash Pool	-	-	-	-	-	-	James	-	-	Today no pool reading taken due pump failure at KBBC
Tuesday	13-Mar-18	7.30am	Main	-	-	-	1.78	7.75	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		-	Small	-	-	-	2.90	7.70	1 Scoop&300g	James	-	-	-
-	-	-	Splash Pool	-	-	-	-	-	-	James	-	-	Today no pool reading taken due pump failure at KBBC
Wednesday	14-Mar-18	7.30am	Main	-	-	-	2.40	7.30	7 Scoop	Kamarau	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		-	Small	-	-	-	2.30	7.85	1 Scoop&300g	Kamarau	-	-	-
-	-	-	Splash Pool	-	-	-	-	-	-	Kamarau	-	-	Today no pool reading taken due pump failure at KBBC
Friday	16-Mar-18	7.19am	Main	-	-	-	2.60	7.90	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		-	Small	-	-	-	2.80	7.60	1 Scoop&300g	James	-	-	-
-	-	-	Splash Pool	-	-	-	-	-	-	James	-	-	Today no pool reading taken due pump failure at KBBC
Monday	19-Mar-18	7.06am	Main	-	-	-	2.40	7.90	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		13.40pm	Small	-	-	-	2.10	8.00	1 Scoop&300g	James	-	-	-
-	-	-	Splash Pool	-	-	-	1.00	7.20	-	James	-	-	-
Tuesday	20-Mar-18	7.20am	Main	-	-	-	2.40	7.60	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		13.35pm	Small	-	-	-	2.06	7.60	1 Scoop&300q	James	-	-	-
-	-	-	Splash Pool	-	-	-	1.00	7.30	-	James	-	-	-
Wednesday	21-Mar-18	7.15am	Main	-	-	-	2.40	7.80	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		13.37pm	Small	-	-	-	2.80	7.85	1 Scoop&300q	James	-	-	-
-	-	-	Splash Pool	-	-	-	1.00	7.20	-	James	-	-	-
Thursday	22-Mar-18	7.20am	Main	-	-	-	2.70	8.00	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		13.25pm	Small	-	-	-	3.30	8.35	1 Scoop&300g	James	-	-	-
-	-	-	Splash Pool	-	-	-	1.10	7.30	-	James	-	-	-
Friday	23-Mar-18	7.15am	Main	-	-	-	2.50	7.75	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		11.00am	Small	-	-	-	3.20	7.90	1 Scoop&300g	James	-	-	-
-	-	-	Splash Pool	-	-	-	1.30	7.30	-	James	-	-	-
Monday	26-Mar-18	7.30am	Main	-	-	-	3.70	7.85	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		10.45am	Small	-	-	-	3.20	7.80	1 Scoop&300g	James	-	-	-
-	-	-	Splash Pool	-	-	-	1.00	7.10	-	James	-	-	-
Tuesday	27-Mar-18	7.19am	Main	-	-	-	2.60	7.90	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		13.20pm	Small	-	-	-	3.70	7.55	1 Scoop&300g	James	-	-	-
-	-	-	Splash Pool	-	-	-	1.10	7.20	-	James	-	-	-
Wednesday	28-Mar-18	7.16am	Main	-	-	-	2.70	7.95	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		13.30pm	Small	-	-	-	3.30	8.05	1 Scoop&300q	James	-	-	-
-	-	-	Splash Pool	-	-	-	1.00	7.20	-	James	-	-	-
Thursday	29-Mar-18	7.19am	Main	-	-	-	2.70	7.45	7 Scoop	Kamarau	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		13.25pm	Small	-	-	-	4.40	7.90	1 Scoop&300g	Kamarau	-	-	-
-	-	-	Splash Pool	-	-	-	1.20	7.20	-	Kamarau	-	-	-
Friday	30-Mar-18	7.20am	Main	-	-	-	2.80	7.85	7 Scoop	James	-	-	Dosing Chemical for both pool calcium Hypochlorite approx 21.00hrs
		14.25pm	Small	-	-	-	3.30	8.00	1 Scoop&300g	James	-	-	-
-	-	-	Splash Pool	-	-	-	1.00	7.30	-	James	-	-	-